

FORM Standard: Hot Work

HOT WORK FIRE WATCH CHECKLIST

Checklist completed by:	Date:
Supervisor:	
	Completed:
There is no evidence of burning or smoldering material.	
Familiarize yourself with the Emergency Evacuation Plan, exit routes and alar building where hot work operations are being performed.	m locations in the
Ensure that an appropriate fire extinguisher is readily available in the hot worl	x area.
Verify with the Hot Work Operator what type of activity they will be doing and precautions prior to the start of the work.	take necessary □
Verbally communicate to all employees that hot work activities are being condu	ucted in the area. \Box
Ensure that there are no flammable materials near the work area. Flammable relocated at least 35 ft. from the work area.	materials must be
Ensure that materials which cannot be relocated 35 ft. from the work area are blanket prior to conducting hot work.	covered with a fire □
Assist the Hot Work Operator with identifying holes in the floor or walls where can enter. Ensure that these locations are covered prior to conducting work.	e hot sparks and slag □
Position yourself in a manner that allows you to remain visible to the Hot Wor employees and personnel who may enter the work area.	k Operator and other □
Monitor sparks and slag produced by the hot work and ensure that they do not materials or other employees working in the area.	land near flammable
Detain anyone attempting to pass through the work area until the hot work can	n be suspended. \Box
Alert the Hot Work Operator if anyone enters the work area. Suspend hot work the area is clear again.	activities until □
DO NOT leave your post until you are relieved by another trained fire watch. In emergency all hot work activities must be suspended.	n the event of an □
Remain in the work area for least 60 minutes* after hot work is completed.	

*Increased to 60 minutes based on revisions to the 2019 Edition of NFPA 51B