



HARVARD UNIVERSITY

Higher Education Opportunity Act - "On Campus" Residential Housing Fire Log

DATE FIRE WAS REPORTED	NATURE OR CAUSE OF FIRE	DATE AND TIME OF OCCURRENCE	SCHOOL/OWNER	BUILDING NAME/ADDRESS	DETAILED LOCATION OF FIRE
01/25/2018 10:00 AM Fire alarm received – activated sprinkler head.	Electric bicycle lithium battery Over charged or damaged battery No injuries	01/25/2018 10:00 AM	Harvard University Housing & Harvard College	22-24 Prescott Street Cambridge, MA	Telecommunication closet located in the basement
3/19/2018 Smoke observed by EH&S Staff – Call to Cambridge Fire Department - HUPD.	Leaves Improper disposal of cigarette-ignited leaves in an exterior window well. No injuries – No damage	3/19/2018 11:58 AM	Harvard University Housing HUH	Peabody Terrance 204 Banks Street Near Entry #31	Window well Exterior of building



Higher Education Opportunity Act - "On Campus" Residential Housing Fire Log

<p>4/30/2018</p> <p>Fire Alarm Received.</p> <p>Smoke observed from windows – exterior.</p> <p>Sprinkler heads NOT activated</p>	<p>Unattended Open Flame Candle</p> <p>Significant soot damage</p> <p>No injuries</p>	<p>4/30/2018 7:20 PM</p>	<p>Harvard University Housing HUH</p>	<p>One Western Ave 2nd floor Court</p>	<p>Bedroom</p>
<p>10/3/2018</p> <p>Fire Alarm Received 11:36 AM</p>	<p>Smoke observed in basement - Telecommunication closet located in the basement</p> <p>Fire maybe related to power supply, possible switch failure.</p>	<p>10/3/2018 11:36 AM</p>	<p>Harvard College</p>	<p>Weld Hall Harvard Yard Basement</p>	<p>Telecommunication closet located in the basement</p>
<p>1/21/2019</p> <p>Fire alarm received 4:00 PM</p> <p>Smoke detectors activated</p>	<p>Unattended cooking – grease fire on stovetop.</p> <p>No injuries</p> <p>Damage limited to back splash and exhaust fan. Unit to be replaced</p>	<p>1/21/2019 4:00 PM</p>	<p>Harvard Medical School HMS</p>	<p>Vanderbilt Hall 107 Avenue Louis Pasteur</p>	<p>Common Kitchen Area</p>



Higher Education Opportunity Act - "On Campus" Residential Housing Fire Log

<p>4/23/2019 Fire alarm received at 9:30 AM</p>	<p>Unattended toaster oven No injuries Damage limited appliance</p>	<p>4/23/2019 9:30 AM</p>	<p>Harvard Medical School HMS</p>	<p>Vanderbilt Hall 107 Avenue Louis Pasteur</p>	<p>Common Kitchen Area near office 116</p>
<p>7/13/2019 Fire alarm received at 14:45</p>	<p>Unattended stove top No Injuries Damaged limited to electric stove and hood/cabinet</p>	<p>7/13/2019 14:45</p>	<p>Harvard University Housing HUH</p>	<p>10 DeWolfe Street Cambridge, MA</p>	<p>Second floor unit</p>
<p>7/21/2019 Fire alarm received at 2:54</p>	<p>Electrical fire in high tension electrical vault located in mechanical room No injuries Damaged contained within the switch gear equipment</p>	<p>7/21/2019 2:54</p>	<p>Harvard College</p>	<p>Thyer Hall Harvard Yard Cambridge., MA</p>	<p>Basement mechanical high-tension electrical vault</p>